

LP/PROPANE TANKS

Second Class Permit Required

Woodhaven Rules and Regulations, Article VIII, Section 12

- A. NFPA 58-2004, Liquefied Petroleum Gas Code requires that the discharge from relief valve, vent discharge, and filling connection on either DOT cylinders or ASME containers filled at the point of use not be less than 10 feet in any direction from any exterior source of ignition, openings into direct vent appliances, or mechanical ventilation air intakes. Replacement containers filled at vendor shall not be less than 5 feet from the above features.
- B. LP containers and fire pits must be a minimum of 20 feet apart in any direction including neighboring campsites.

Setbacks: 15' from front, 7' from side and rear property lines.